SIEMENS



Web-Server

For LPB/BSB plants

OZW672... V8.0

Web server OZW672... allows for remote plant control and monitoring via the web and Smartphone-App. Web server is available in three versions: To connect 1 LPB/BSB unit or 4 or 16 LPB units for the Sigmagyr / Albatros and Albatros2 ranges.

- Operate via web browser with PC/laptop and Smartphone
- Operate via Smartphone app (iPhone and Android)
- Operation via Internet portal with auxiliary functions
- Plant visualization in the web browser based on customized plant web pages
- Connection types: USB and Ethernet
- 2 digital inputs for fault messages
- Display fault messages in the web browser
- Send fault messages to a maximum of 4 e-mail recipients
- Periodically send system reports to maximum of 4 e-mail recipients
- Create trends, trend graphs and send trend data to 2 e-mail recipients
- Function "Energy indicator" to monitor data points for energy-related limit values, or "Green limits" and send to 2 e-mail recipients

	 Web services for external applications via Web API (Web Application Programming Interface) Encrypted with https and TLS for emails ACS790 functionality Secure tunnel connection for ACS via portal Time sync via NTP network time server
Use	
Buildings	 Apartments in single and multi-family homes. Office and administrative buildings, residential housing. Schools, gymnasiums, leisure facilities, hotels. Municipal buildings, commercial and smaller industrial buildings.
Owners/operators	 End customers, HVAC and electrical installers, heating manufacturers. Real estate agencies, real estate management companies, service organizations. Building maintenance companies, facility management.
Functions	
Commissioning	Commissioning is carried out via PC/Laptop and Web browser or ACS. A quick commissioning mode is available on plants with only a single connected controller.
Web operation	 Remotely operate and monitor plants and devices on a LPB/BSB network using a web browser on PC/laptop and Smartphone. Access via Internet portal or direct connection Simultaneous support of multiple users. User accounts for web operation (user groups, operating language). Set up customized plant web page features.
Access via portal	Siemens offers with the Climatix IC / Synco IC Internet portal simple and secure access to web servers (available as of web server version 5.2).
Benefits	 Simple and fast set up of access via the Internet – neither a fixed IP address, nor forwarding of a dynamic IP address, nor port forwarding (NAT/PAT) is required The portal provides additional functions: Manage one or multiple plants Central user management Display of plant overview, state of Energy indicators, and alarms Plant functional scope can be set for various plant roles Logging fault messages as common faults Send alarm notifications per e-mail Secured communications through encryption (https)
Access without portal (direct connection)	The web server can be accessed directly via the Internet (without using the portal). A fixed IP address to the web server is required or a dynamic IP address with forwarding via a dynamic DNS server. In addition, the port forwarding must be configured on the router.
	A direct connection in parallel to the portal is also possible.

Web interface

User interface portal

The web server interface is the same using the portal or via a direct connection. The portal has, however, additional functions and available settings.

IEME	NS						Sien	nens Proxy	 English (Unit 	ted Kingdom) 🔻	name@exar	nple.com	٠
Dashboards	Operating	Administrat	ion										
perating > O	.Z.W. Retail Gr	mbH. (zählerwe	g 3, Zug, LPB,	BSB, English)	 Web access 								
larms												Ċ	Ċ
/eb access		SIEME	NS										
ocumentation						09	.01.2018	12:25	p	۰			
		Home	Energy indicate	or Faults	File transfer	User accounts	Device we	b pages		🛆 name@	example.com		
				Home > 0.6 OZW6	72.16 > Settings > Com	munication > Ethernet							
		1 Upward		Dat	apoint					Value			
		🕒 LPB/BSB		DH	CP client					On	0		
		Ethernet		IP a	ddress					192.168.2.43			
		🗗 E-mail		Sut	onet mask					255.255.255.0			
		🗗 USB		Det	ault gateway					192.168.2.1			
		Services		Pre	ferred DNS server					192.168.2.1			
				Alte	ernate DNS server								
				Set when DHCP c	lient off								
				IP a	ddress					192.168.2.10	0		
				Sut	onet mask					255.255.255.0	0		
				Det	ault gateway					192.168.2.1	0		
				Pre	ferred DNS server					192.168.2.1	0		
				Alte	ernate DNS server						0		
												147	

Click the symbol ^{CC} to open the web server user interface under a new tab and is then the same as the view under a direct connection.

The portal symbol and e-mail address is displayed in place of the user symbol and user name.

User interface
web server
(Direct connection)

SIEMENS

				09.01.2018	12:26	P		
Home	Energy indicator	Faults	File transfer	User accounts	Device web	pages	[Logout] Administrator	r
	н	lome > 0.6 OZW67	2.16 > Settings > Com	munication > Ethernet				
L Upward		Data	apoint				Value	
🕒 LPB / BSB		DHC	P client				On	0
🕒 Ethernet		IP ac	ldress				192.168.2.43	
🕒 E-mail		Sub	net mask				255.255.255.0	
🗗 USB		Defa	ault gateway				192.168.2.1	
Services		Pref	erred DNS server				192.168.2.1	
		Alte	rnate DNS server					
		Set when DHCP cli	ient off					
		IP ac	ddress				192.168.2.10	Ø
		Subi	net mask				255.255.255.0	Ø
		Defa	ault gateway				192.168.2.1	0
		Pref	erred DNS server				192.168.2.1	0
		Alte	rnate DNS server					0
		Phys	sical address				00:a0:03:fd:27:f0	
								Ħ

Primary navigation	Primary navigation offers the following functions:					
	Home	Menu-based plant and device operation.				
	Energy indicator	Display and operate "Energy indicator" data points.				
		(displayed only if a controller is connected with an Energy indicator)				
	Faults	Display system faults.				
	File transfer	Create and manage trend functions				
		Download consumption data and event history,				
		Upload documents, logos and system definitions as well as firmware update.				
	User accounts	User administration.				
	Device web pages	Create device list and operating pages.				
Secondary navigation	The secondary r pages.	navigation (menu tree) allows users to select devices and operating				
Display	The display rang secondary navig	The display range displays content corresponding to the selected primary and secondary navigation.				
Plant state	The display indic plant state.	The display indicates no fault or the most serious plant fault depending on plant state.				
Faults						
Fault sources	The web server recognizes failures and fault signals from LPB/BSB devices contained in the device list. Faults from digital inputs and own faults are detected also.					
Fault indication	The LED $oldsymbol{4}$ sigr is present.	The LED Δ signals a fault on the web server. The LED is lit for as long as the fault is present.				
Fault status message	Fault status messages can be sent as an e-mail to as many as 4 e-mail recipients and/or via a service provider to SMS recipients. You can set the fault priority for each email recipient (urgent/all). Each receiver has a "Time switch with calendar" to program three sending times per day and holidays/special days.					
Common fault	On the Climatix IC/Synco IC Internet portal, faults are logged as common faults. The portal sends alarm notifications to the defined e-mail addresses in the event of a common fault.					

System report	
System messages	The web server generates system reports and periodically sends the system state to e-mail recipients. Messages are sent as per the set time (hh:mm), the message cycle interval (1255 days), and priority (urgent/non-urgent).
Connection test	Press the V button on the web server to send a system report to all defined email recipients regardless of fault priority.
History	The last 500 fault events, fault messages and system reports are entered in the web server's circular message buffer. The events or history data can be read via web browser.
Time	The web server has a system clock with adjustable daylight saving/standard time changeover. It can send the time (date and time) as the time clock master to the LPB devices (time clock slave). For the system clock, the NTP network time server can perform the time synchronization and, if used as a time clock master, forward the data to all KNX devices (time clock slaves).
Updates	 We differentiate between the following: System definition updates to integrate device descriptions of new devices in the web server. Firmware updates to update the web server to the latest firmware version. The user settings and system definitions remain as part of a firmware update. Factory update to the web server to the latest version and load the latest system definitions. User settings are lost as part of a factory update. A system definition update and the firmware update requires one simple action via the web browser. Operator actions on the web server are required for the factory update. Procedures are communicated when a factory update is issued.
ACS790	The web server is compatible with the service and operating software ACS790 version 10.00 and higher.
Secured connection via portal	On web servers as of V7.0, you can establish a secure connection to the web server with the ACS790 and the "Remote Tool Access" software via the Climatix IC / Synco IC portal.

Visualize plants

Web server OZW672... allows for visualizing technical equipment in buildings via plant web pages. For example, a plant web page can be set up visualizing a plant with data points (max. 100 data points per plant web page) on a floor plan. In the event of a fault, users can quickly access the impacted locations.

For writable parameters, users can click to open a dialog box and change the parameter (as e.g. the "Room temp reduced setpoint" displayed below).



Example Plant web page for heating plant

Import plant diagrams For standard LPB/BSB controller applications, web-capable plant diagrams can be exported from ACS790 and imported in the web server.

Create own plant web pages

You can freely design plant web pages. As a hybrid form, you can also modify and extend downloaded plant diagrams.

Web page elements Users can also embed additional data in a plant diagram such as links to plant, function and maintenance descriptions or data sheets. Moreover, users can integrate external links allowing, for example, to directly browse multiple plants. Users can embed current webcam images in a plant diagram.

- Trend functionThe trend function in Web-Server OZW672... can be directly defined on Web
server version 5.0.
Using the trend functions, you can log and query any number of data points from
connected devices as a selectable sample rate.
- Trend channels 5 trend channels are available. Each trend channel can contain up to 100 data points. The trend channel can be labeled using a free text name.

Sample rateThe sample rate can be individually created for each trend channel. Available
sample rates ranging from 1 s up to 24 hours.
The shortest possible sample rate over all 5 trend channels is 1 data point per
second.

Trend period RAM size determines possible trend periods for a channel. The trend period varies with the number of selected data points and their sample rates.

Examples for various trend channels:

Interval	Data points	Trend period		
		Channel 1	Channel 25	
1 sec	1	14 days	1.8 days	
5 sec	5	30 days	4.3 days	
1 min	10	210 days	30 days	
15 min	100	371 days	53 days	

Trend channel 1 has 7 times the available memory for long-term trends or trends with a lot of data points or a short sample interval.

SynchronizationTrends are synchronized to simplify evaluation of trend data. The various query
intervals for the trends are placed on an interval grid.

Operation

The web browser or ACS tool is used to create and manage trend functions.

SIEMENS

OZW672.01			31.	.01.2018 14:27	P		A
Home Energy indica	ator Faults	File transfer	User accounts	Device web pages			Logout] Admin
l≃ Trend	Name		State	Query interval	Circular logging	Bus load	Action
Message history	Outside temperature	• •	🗠 Running	2m	>730 Days	1 %	B
Documents	Roomtemp setpoint	■ ↓ □	🗠 Running	5m	728 Days	0 %	B
Logos	Room temperature	■ ↓ □	🗠 Running	5m	728 Days	0 %	B
arphi Updates	DHW setpoint	ta 🗸	🗠 Running	10m	>730 Days	0 %	B
	DHW temperature	■ V.	🗠 Running	10m	>730 Days	0 %	B
			-			2%	Current bus load

Data query per web browser

A web browser allows you to download trend data for each channel and view it in a spreadsheet program or text editor. A calendar function allows limiting trend data t the desired period within trending.

Web server can be accessed locally or via the Internet.

Trend graph Data for a trend channel can be graphically displayed on the web user interface. The function is available for OZW672... as of version 6.0.



Data transmission per
e-mail2 e-mail recipients can be defined for trend data. Each trend channel can send its
data to one or both e-mail recipients.

The send interval can be individually set for each trend channel.

Import/export

Trend definitions can be imported to web server or exported from the web server.

Function "Energy indicator"	Function "Energy indicator" is available on the OZW672 web server from V4.0.						
	The web server uses the "Energy indicator" function to read selected data point values from the LPB and BSB bus devices and to compare the values to energy-related limit values, or so-called "Green limits".						
	The data points are also monitored for adherence to the "Green limits". As a result, the "Energy indicator" is displayed in the form of a tree leaf.						
Note	The "Green limits" are used only together with the "Energy indicator" function. They do not represent process or safety limit values which trigger e.g. fault messages or turn off the plant in the event of limit violations.						
Web server, e-mail	The "Energy indicator" can regularly send its information (set via the web server) to a maximum of 2 e-mail recipients.						
Tree leaf as							
	"Green leaf" \rightarrow Green tree leaf, leaf pointing up.						
Green leaf	• The "Green leaf" symbol indicates that a data point value has not exceeded its "Green limit", i.e. the value is within a "green" range in terms of energy consumption.						
	"Orange leaf" \rightarrow Orange tree leaf, leaf pointing down.						
Orange leaf	 The "Orange leaf" symbol indicates that a data point value has exceeded its "Green limit", i.e. the value is outside a "green" range in terms of energy consumption. 						
Standard EN 15232	The "Energy indicator" function is based on standard EN 15232 "Energy efficiency in buildings".						
Example: Web page "Energy indicator"	Web page with "Energy indicator" function; example with data points from "Heat circuit 1" and open dialog box to set data point value "Room temperature Comfort setpoint HC 1" and its "Green limit".						
	SIEMENS						
	15.01.2018 10:50 🧖 🐥						
	Home Energy indicator Faults File transfer User accounts Device web pages Energy indicator > 1.10 RV561.843E/109 > Heating circuit 1						

Upward Energy indicator Datapoint Value Green limit(s) P **~** Operating mode heat circuit 1 Automatic Protection, Automatic, Reduced, Heating circuit ø **~** 22.0 °C 0 22 °C Room temperature Comfort setpoint HC1 ø 19 °C **v** Room temp reduced setpoint heat circuit 1 18.0 ℃ Ø P **~** Su Room temperature Comfort setpoint HC1 0 19 °C **22.0** Value •• Т è 18.0 °C 35.0 °C Green limit(s) 22.0 ОК Cancel

Web services



Type summary

The "Web Application Programming Interface" (Web API) is an interface to make web services on a web server accessible to clients.

All Web API functions are called up via "http" or encrypted "https". Each session begins with authentication on the web server.

If the "HomeControl IC" App" installed on a smart phone, the web services can access the data points of the devices on the LPB network via the Web API (communication connection for smart phone see page 11).

Name		Product number
Web server	for 1 LPB/BSB device	OZW672.01
Web server	for 4 LPB devices	OZW672.04
Web server	for 16 LPB devices	OZW672.16

Ordering and delivery

When ordering, please specify the name and product number.

Example: Web server **OZW672.16**

The web server is delivered in a cardboard box.

The following is included in the package:

- Mounting instructions M5712xx.
- Power cable, power supply AC 230 V.
- Ethernet cable.
- USB cable.
- 2 cable ties.

LPB/BSB devices	 The following devices from the Sigmagyr/Albatros product range can be connected to each OZW672 web server via LPB/BSB. Heating controllers RVL4, RVP3 District heating controller RVD2 Universal controller RVP5 Heating controllers RVA, RVS, RVC Boiler management units LMU, LMS
Note	Download a detailed list of compatibility of LPB/BSB devices from <u>https://support.industry.siemens.com/cs/ww/en/view/62567396</u> .

Product documentation

	Document type	Document no.
Web server OZW672	Data sheet (this document)	N5712
	Mounting instructions (package insert)	M5712
	Installation instructions	G5711
	Commissioning instructions	C5712
	CE declaration of conformity	T5711
	Environmental product declaration	E5711
ACS790 software	Data sheet	N5649

Technical design

Web browser	Devices	Demand
	PC/Laptop (1024 x 786)	html5 compatible web browser
	Smart phone	Specific to the particular end device
	•	

Concurrent operation Concurrent operation is unlimited. The maximum data throughput is shared between the users. Operation slows down as the number of users increases accordingly.

Operation, monitoring, alarming

Communication connections for local commissioning (USB) and remote operation, remote monitoring and alarming via Ethernet.

The web server is not suited for direct connection to the Internet, but rather must be connected via a firewall. A router typically includes a firewall.



Interfaces

USB	The USB interface directly connects the PC/laptop on site. The required USB cable type A – type Mini-B is delivered with the device.
Ethernet	The router/network is connected to the Ethernet RJ45 plug. The Ethernet interface features Auto-MDI(X) for crossed and non-crossed Ethernet cables. An Ethernet category 5 cable is supplied.
LPB/BSB	The LPB/BSB bus is connected to terminals DB/CL+ and MB/CL For information on the LPB/BSB bus, see Local Process Bus System Engineering, basic documentation P2370.
Digital inputs	The digital inputs D1, D2 help connect potential-free status contacts. They work as fault inputs.
Protocols	
Web operation	Web operation via portal takes place through an HTTPS encrypted connection (Port 443) via TCP/IP. The required certificate is accredited.
	Web operation without portal takes place through an HTTPS encrypted connection (Port 443) via TCP/IP. The required certificate is not accredited. The self signed certificate by Siemens is saved to the web server and cannot be changed.
	In addition, an HTTP (Port 80) connection is supported. Port 80 is disabled as delivered. The access via http is not secured. The user is responsible for enabling Port 80.
	A RNDIS driver on the PC/laptop is required for USB communication. The RNDIS driver is already included in the Windows operating systems for web server as of version 7.0.
Send email	Fault messages and "Energy indicator" reports and trend files are sent in an email via SMTP. The email is encrypted using TLS if supported by the mail server.
DHCP client	The web server can be manually configured or take over its network configuration as a client of a DHCP server.

Design

The web server consists of the housing lower section with printed circuit boards and interfaces as well as connection terminals. The upper housing section contains the printed circuit boards. The upper housing section contains the LED displays and one operating button. The connection terminals and additional display and operating elements are located under the removable cover for the upper housing section. All display and operating elements are labeled.



Operating buttons			
6 Remote 🗸	• Long (> 6 s)	Sends system reports to the email recipient of the fault (not to Energy indicator and trend data recipient)	
7 Service	 Short (< 2 s) Long (> 6 s) 	State query device 0.1 (LPB) or 1 (BSB) Quick commissioning of plants with only a single connected controller	
Button combination			
✔ and 💽	 Long (> 6 s) 	Simultaneously press buttons ✓ and ● to restore the device to the factory settings.	
Notes			
Mounting	You can mount the space for wiring w the unit is ventilate • Standard moun • Wall mounting. • Mounting positio • Mounting and d	e web server in a panel, distribution box, or on a wall. Include hen planning. Make sure service can easily access the unit and ed properly. ting On standard rail TH 35-7.5. Attached with 2 screws. on Horizontal or vertical. imensions See "Dimensions".	
Install			
Important notes	 Observe the following when installing: Run fuses, switches and wiring as per local regulations for electrical installations. We do not recommend plant monitoring via USB interface in environments with strong electromagnetic interference (e.g. in industrial environments with electrical welding equipment). See "Technical data" for electromagnetic compatibility. 		
Operating voltage	The supplied AC 230 V power supply provides the DC 24 V operating voltage for the web server.		
Wiring	The operating voltage, USB and Ethernet plugs are located on the upper part of the housing. The terminals on the device for the LPB/BSB bus are located under the removable cover.		
Connection terminals	The connection te sections of 0.25	rminals are designed for wire diameters of min. 0.5 mm or cross- 1.5 mm ² or stranded wire cross-sections of 0.251.0 mm ² .	

Commissioning

Connections	Web-Server is commissioned directly via the portal with a PC/Laptop. A web browser required on the PC/Laptop.	
	The web server can be commissioned locally via USB or with ACS790 . The supplied USB cable type A – Type Mini-B connects the web server to the PC/laptop.	
	A quick commissioning mode is available on plants with only a single connected controller. Press the button to add a controller to the device list with address 0.1 (LPB) or 1 (BSB) and generate its device web page.	
	Additional information is available in the Mounting instructions M5712 inserted in the package or the Installation guide G5712 and commissioning instructions C5712, available in the Download Center at: <u>http://www.siemens.com/ozw672-manual</u> .	
Router	You need a suitable router for remote operation via Internet. The router must support NAT/PAT to access via the portal or via a direct connection using a fixed IP address. For a direct connection using a dynamic IP address, it must also support a dynamic DNS server.	
IP address	 The IP address via USB is set: 192.168.250.1. Default setting for the IP address via Ethernet: 192.168.2.10. The network administrator must provide an IP address for the web server before you can connect the web server via Ethernet to a managed network. 	
User groups	User accounts are created and assigned to specific user groups for customized user operation.	
End-user	 Access to end-user data and fault overview. Operate and monitor via menu tree and plant diagrams. Administer own user accounts. 	
Technical service	Same as end user. In addition:	
	 Access service data. Create, download, and manage trend data Download consumption data and message history. Upload customized logos and documents. System definitions update. Firmware update Update device web pages. 	
Administrator	Same as service. In addition:	
	 Edit device list. Create device web pages. Create, copy, change, and delete plant diagrams. Select "Energy indicator" data points and change the default values of the data points and/or "Green limits" as needed. Administer all user accounts. 	

Maintenance	The OZW672 web server is maintenance free (no battery changes, no fuses). Clean the housing only with a dry towel.
Repair	The OZW672 web server cannot be repaired on site. If faulty, return to the Repair Center at the relevant Regional Company.

Disposal



The device is considered electrical and electronic equipment for disposal in terms of the applicable European Directive and may not be disposed of as domestic garbage.

- Use only proper channels to dispose the device.
- Comply with all local, applicable laws and regulations.

Technical data

Power cable for web server OZW672 Operating voltage Rated voltage "Euro plug" AC 230 V ± 15 % AC 230 V	20-1	
Frequency 50/60 Hz		
Power consumption (including web server OZW672) 3 VA typical		
Protection class II.		
Output voltage SELV 24 VDC		
Supply line fusing Max. 16 A		
Cable length (distance from AC 230 V plug to web server) Max. 1.6 m		
Web server OZW672 Operating voltage SELV 24 VDC ±5 %, 62	25 mA max.	
Power consumption 2 W typical		
Functional data Min 72 hours		
Pulicional data diotenserve million 2 hours		
OZW672.01 1 LPB/BSB device		
OZW672.04 Max. 4 LPB devices		
OZW672.16 Max. 16 LPB devices		
LPB/BSB bus Interface type 2-wire connection 2-wire bus DB/CL+, MB/CL- (non-4 Bus load E 5	exchangeable)	
Permissible line length and cable types See: Local Process Bus, Sys ing, Basic documentation	stem engineer- on P2370	
Connection, screw terminals for Solid/stranded wire (twisted or with ferrule)Min. dia. 0.5 mm1 solid wire per terminal0.251.5 mm² 0.251.0 mm²		
USB Interface type USB V2.0		
Device class RNDIS		
Baud rate Max. 12 Mops (ruil spec	ea)	
Cable length Max 3 m		
Cable type for connection to PC/laptop USB type A		
Cable type for connection to OZW672 USB type Mini-B		
EthernetInterface type100BaseTX, IEEE 802.Bit rateMax. 100 MbpsProtocolTCP/IP	3 compatible	
Identification Auto MDI-X		
Connection, plugRJ45 plug (screened)Cable typeStandard Cat-5, UTP orCable lengthMax. 100 m	STP	
Directives and standards Product standard EN 60950-1 Information technology Safety	equipment –	
EU conformity (CE) CE1T5711xx [*]		
RCM conformity CE1T5711en_C1 *)		
EAC conformity Eurasia conformity		
Environmental The product environmental declaration CE1E5711en ^{°)} contains data on environmentally compatibility The product design and assessments (RoHS compliance, materials composition, packaging, e benefit, disposal).	The product environmental declaration CE1E5711en ⁵⁾ contains data on environmentally compatible product design and assessments (RoHS compliance, materials composition, packaging, environmental benefit, disposal).	
Degree of protection Protective category IP30 to EN 60529		
Protection class III on per EN 60050 1		

*) The documents can be ordered at http://siemens.com/bt/download.

Degree of protection	Protective category	IP30 to EN 60529
	Protection class	III as per EN 60950-1
Ambient conditions	Operation Climatic conditions Temperature (housing and electronics) Humidity Mechanical conditions	IEC 60721-3-3 Class 3K5 050 °C 595 % r. h. (non-condensing) Class 3M2
	Transport Climatic conditions Temperature Humidity Mechanical conditions	IEC 60721-3-2 Class 2K3 –25+70 °C <95 % r. h. Class 2M2
Materials and colors	Upper housing section	PC + ASA, RAL 7035 (light-gray)
	Lower housing section	PC + ASA, RAL 5014 (dove blue)
Dimensions	Length x width x height (max. dimensions)	87.5 mm x 90.0 mm x 39.2 mm
Weight	Web server OZW672 Web server with packaging, installation instructions,	0.136 kg
	power unit, USB and Ethernet cable, cable ties.	0.589 kg
	Packaging	Cardboard box
Terms, abbreviations	Auto Medium Dependent Interface - Crossed	Auto-MDI(X)
	Boiler System Bus	BSB
	Dynamic Domain Name System	DynDNS
	Dynamic Host Configuration Protocol	DHCP
	HVAC Integrated Tool von Siemens	HIT
	Hyper Text Transfer Protocol	HTTP
	Hyper Text Transfer Protocol Secure	HTTPS
	Internet Protocol	IP
	Local Process Bus	LPB
	Network Address Translation	NAT
	Network Time Protocol	NTP
	Port and Address Translation	PAT
	Remote Network Driver Interface Specification	RNDIS
	Shielded Twisted Pair	STP
	Simple Mail Transfer Protocol	SMTP
	Transport Layer Security	TLS
	Transmission Control Protocol	TCP
	Universal Serial Bus	USB
	Unshielded Twisted Pair	UTP
	Web Application Programming Interface	Web API

Connection diagrams

Connection diagram



- N1 Web server
- N2 LPB/BSB device

P1, P2 Devices with potential-free contact output for fault indication

Connection terminals

LPB/BSB bus Digital inputs



LPB/BSB		Dig	Digital	
1	DB/CL+	1	D1	
2	DB/CL+	2	Μ	
3	MB/CL-	3	D2	
4	MB/CL-	4	М	

Operating voltage DC 24 V 1 DC 24 V (+) 2 GND (-)

Dimensions



Published by: Siemens Switzerland Ltd. Building Technologies Division International Headquarters Theilerstrasse 1a 6300 Zug Switzerland Tel. +41 58-724 24 24 www.siemens.com/buildingtechnologies

© Siemens Switzerland Ltd 2018 Delivery and technical specifications subject to change